

- 10" ROUND GREEN PLASTIC VALVE BOX, CARSON—BROOKS 910 OR EQUAL
- (2) INSTALL BOX AT FINISH GRADE IN TURF AREAS, 2" ABOVE GRADE IN PLANTING AREAS
- 3 QUICK COUPLER SEE EQUIPMENT SCHEDULE (MOUNT 4 6" BELOW GRADE)
- (4) 1" GALVANIZED RISER, LENGTH AS REQUIRED
- (5) 6" MIN. DEPTH CLEAN PEA GRAVEL
- (6) MAIN SUPPLY LINE
- (7) SUB-GRADE COMPACTED TO 90% (TYP.)

- (8) 1" GALVANIZED DOUBLE ELBOW SWING JOINT
- 9 1" GALVANIZED NIPPLE, MIN. LENGTH 24" BEFORE TRANSITION TO PVC PIPE
- 10) 1" BALL B11444 FORD VALVE
- (11) SCH. 80 NIPPLE
- 2" SCH. 40 PVC SLEEVE NOTCHED OVER BALL VALVE
- 906L WEATHERMATIC LOCKING VALVE CAP PERMANENTLY ATTACHED TO SLEEVE. TOP OF MARKER 4" - 6" BELOW GRADE

NOTE: INSTALL (1) QUICK COUPLING VALVE AT ALL VALVES BANKS AS SHOWN ON PLANS.

QUICK COUPLING VALVE ASSEMBLY

HYDE PARK CITY

113 EAST CENTER HYDE PARK, UTAH 84318 TEL: (435) 563–6507





QUICK COUPLING VALVE ASSEMBLY

IR - 04