

# Fireworks Stand Inspection

## Rupert Fire Department

Roger Davis – Fire Chief

\_\_\_\_\_ License and Permit on Display

\_\_\_\_\_ 2 Extinguishers (at least 2A rating each)

\_\_\_\_\_ No Smoking Signs on all Four Sides

\_\_\_\_\_ No Person 16 or Younger Inside Booth

\_\_\_\_\_ 21 y/o Supervisor at all Times

\_\_\_\_\_ No Building Within 25 ft. of Stand

\_\_\_\_\_ 2 exits (30") wide

\_\_\_\_\_ Over 32 Feet, After Every 32 Feet of Rear Wall, Need More Exits

\_\_\_\_\_ All Doors Open Outward

\_\_\_\_\_ No Lighting of Fireworks Within 25 ft. of the Stand

\_\_\_\_\_ Class 1.4G or Less Fireworks Only

\_\_\_\_\_ Fireworks Storage - 25 ft. From Stand

\_\_\_\_\_ Inventory List

\_\_\_\_\_ No Fireworks Left Unattended After the Stand is Closed

\_\_\_\_\_ Only Noncombustible Waste Containers

\_\_\_\_\_ No Fireworks Shall Remain Unattended Regardless of Whether the Stand is Open or Not

\_\_\_\_\_  
Signed

\_\_\_\_\_  
Date